

Air Permeability Test Certificate



This is to certify that the following test and results have been produced in compliance with England and Wales regulation 43 of the Building Regulations 2010, Scotland Section 6 of the Domestic and Non-Domestic Handbook, Northern Ireland Technical Booklet and Isle of Man The Building Control (Approved Documents) Order 2014. A full report in line with the current approved procedures can be requested from the iATS member.

Unique Certificate Number	10034413
Date of Test	18 / 01 / 2017
Building name / Plot number	Hill House
Building Address	The Hill, Westleton, Saxmundham, Suffolk IP173AW
r^2 (Correlation ≥ 0.98 - ≤ 1.00)	0.9990
n (Slope ≥ 0.5 - ≤ 1.0)	0.651
Envelope Area of Building m^2	343
Report Reference	Hill House Rep
Tester's Name	Nathan Kennedy
Company Name	Target Air Testing
Tester's Registration no.	0038

Signed

A handwritten signature in blue ink that reads "N. Kennedy". The signature is written over a white rectangular background.

Independent Airtightness Testing Scheme
Partnership for Learning
Training & Conference Centre
South Road, Liverpool, L24 9PZ

e: certificate@iats-uk.org
t: 0300 688 0016
w: iats-uk.org
Registration No: 09309058

Measured Air Permeability Q50

2.19

$m^3/(h.m^2)$ @ 50 Pa