

# Air Permeability Test Certificate

Test number ..... 01340 ..... BINDT registration number ..... 0038 .....  
Report reference number ..... JN1360APT .....

This is to certify that the following dwelling and test results were carried out fully in compliance with Approved Document L1 of the 2010 Building Regulations

## Dwelling plot/address

Plot 2 Church Road  
House/plot number and road name .....  
Town ..... Elmswell, BSE .....  
County ..... Suffolk .....  
Country ..... England .....  
Post Code ..... IP30 9DY .....

Unit type ..... Detached House .....

Test date ..... 19/10/2015 ..... Test time ..... 11:06 .....

Design air permeability	..... 4 ..... m <sup>3</sup> /(h.m <sup>2</sup> )	r <sup>2</sup> = ..... 0.99371 ..... (>0.98)
Measured air permeability	..... 2.33 ..... m <sup>3</sup> /(h.m <sup>2</sup> )	n = ..... 0.758 ..... (1 ≥ n ≥ 0.5)
Envelope area of dwelling	..... 425 ..... m <sup>2</sup>	

## Accredited tester

Nathan Kennedy  
Name ..... Signature *Nathan Kennedy* ..... Organisation ..... Target Air Testing .....  
Telephone number ..... 01842 860583 ..... e-mail ..... energyassessor@aol.com .....  
Carried out for ..... Svenska Homes ..... (Developer/owner/other)  
Town ..... Ipswich .....  
County ..... Suffolk .....  
Country ..... England .....

Company stamp