

# Air Permeability Test Certificate



This is to certify that the following test and results have been produced in compliance with England and Wales regulation 43 of the Building Regulations 2010, Scotland Section 8 of the Domestic and Non-Domestic Handbook, Northern Ireland Technical Booklet and Isle of Man The Building Control (Approved Documents) Order 2014. A full report in line with the current approved procedures can be requested from the IATS member.

Unique Certificate Number	10030788
Date of Test	14 / 11 / 2016
Building name / Plot number	Filbury Haven
Building Address	Gazeley Road, Moulton, Newmarket, Cambridgeshire CB88SR

$r^2$ (Correlation $\geq 0.98$ - $\leq 1.00$ )	0.9990
n (Slope $\geq 0.5$ - $\leq 1.0$ )	0.593
Envelope Area of Building $m^2$	477

Report Reference	Filbury Rep
Tester's Name	Nathan Kennedy
Company Name	Target Air Testing
Tester's Registration no.	0038

Signed

Independent Airtightness Testing Scheme  
Partnership for Learning  
Training & Conference Centre  
South Road, Liverpool, L24 9PZ

e: [certificate@iats-uk.org](mailto:certificate@iats-uk.org)  
t: 0300 688 0016  
w: [iats-uk.org](http://iats-uk.org)  
Registration No: 09309058

Measured Air Permeability Q50

## 4.73

$m^3/(h.m^2)$  @ 50 Pa